



Office of The Municipal Council Bhandara,
Dist-Bhandara 441904



Phone & Fax: 07184-255093, 07184-252088

Email Id- bhandaranagarpalika@gmail.com

Outward No. MCB/Fire/Safety Approval ///2025

Date: 29/12/2025

FIRE SAFETY APPROVAL

To,
M/s Mother Teresa Public School
Survey No 745/1/B
Kondha/Kosra, Tah. Pauni
Dist- Bhandara

Subject: Grant Sub of "Fire Safety Approval" for your proposed constructed Building of M/s Mother Teresa Public School, Survey No 745/1/B Kondha/Kosra, Tah. Pauni Dist- Bhandara.

Ref: 1. This Office Part Fire Safety Approval Issued vide. No. MCB/Fire/Safety Approval /595/2026 Dt11/08/2025

2. Co. Application, dated 16/10/2025

3. Certificate Submitted by License Agency M/s Samiksha Enterprises Fire Safety Services vide Their Letter Ren/Cer/2387/2025-26, dated 20/10/2025. Form A

4. Inspection Dated 02/12/2025

This has reference to the above. This office has Fire Safety Approval for following Constructed Building of M/s Mother Teresa Public School.

Since the fire fighting arrangements provided is installed by License Agency ie M/s Samiksha Enterprises Fire Safety Services. Mumbai bearing License No.Y88M230007868851 issued the office and has submitted Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Fire Safety Approval" for your following building.

Sr. No.	Floor	Phase I Building
		Height of Building -11.55 Mtrs Build up Area
01	Ground Floor	1453.472 Sq.Mtrs
02	1ST Floor	1453.472 Sq.Mtrs
03	2nd Floor	1453.472 Sq.Mtrs
Built up area in Sq. Mtrs		4360.416Sq.Mtrs

E/Drive/NOC Fire Bhandara World File



Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 17/09/25

It is certified that an inspection team headed by Dr. P.H.C. Kondha

(Name of Officers with designation) from P.H.C. Kondha PHED

inspected the Mother Teresa School Konda Kosara

(Name & Address of the school) on 31.09/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1-22-8-2025 dated 03-09-2025

of (PHED Lab) certified that


the Mother Teresa Public School Kondha (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 17/09/27

Signature with Seal: 

Name : Dr. Kashmiri Madh

Designation : M.B.B.S.

Name & Address of the Office / Department : P.H.C. Kondha

Medical Officer
Primary Health Center Kondha

To Mother Teresa Public

School Kondha
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Senior Geologist Office
Ground Water Survey & Development.
Sub Divisional laboratory, Lakhandur. Dist. Bhandara.

जा.क्र./भुसविय/उपविप्र. लांखादुर/122-08/2025

दि 03/09/2025

WATER ANALYSIS REPORT

Name of Sender - sharad krushnaji humane

Date of Receipt - 05.08.2025

Date of Examination: 18.08.2025

Types of source- R.O .


Location :- *Mother Teresa School Konda Kosari*

(All the Analytical Results are in mg /L.except pH & Turbidity Conductivity)


SR.NO	TEST PARAMETER	BIS Specifications 10500 : 2004 (Edn.2.2) Normal Values		Sample Test Result
		Desirable Limits	Permissible Limits	
1	Physical Observations	--	--	Agreeable
2	Odour	Unobjectionable	--	Agreeable
3	Turbidity (N.T.U.)	1.0	5	0.49
4	Temp	°C	°C	25
5	pH Value	6.5 to 8.5	No Relaxation	7.0
6	Chlorides (as Cl)	250	1000	175
7	Nitrates (as NO ₃)	45	No Relaxation	15.150
8	Total Hardness (as CaCO ₃)	200	600	300
9	Alkalinity (as CaCO ₃)	200	600	260
10	Iron (as Fe)	0.3	1.0	0.001
11	Fluoride (as F)	1.0	1.5	0.500
12	Total Dissolved Solids	500	2000	540
13	Sulphate (as SO ₄)	200	400	49.460
14	EC (Conductivity)	--	--	830
15	Magnesium(Mg)	30	100	68.234
16	Calcium	75	200	19.2


Remark- Above Sample is fit for drinking purpose on the basis of above Analysis.

- ☐ This Report is restricted only for the sample submitted to this laboratory.
- ☐ It is presumed that the representative sample from the source is sent for analysis.


Signature & Seal
Chemist

Sub Divisional Laboratory Lakhandur


Assistant Junior Geologist
G.S.D.A.BHANDARA


Senior Geologist
G.S.D.A. BHANDARA