

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 17/09/25

It is certified that an inspection team headed by Dr. P.H.C. Kondha.....

(Name of Officers with designation) from P.H.C. Kondha.....PHED

inspected the Mother Teresa School, Konda Kosma.

(Name & Address of the school) on 3/09/25.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1-22-8-2025..... dated 03-09-2025

of (PHED Lab) certified that

the Mother Teresa Public School, Kondha (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 17/09/27.....

Signature with Seal: 

Name : Dr. Pashmi Made.....

Designation : M.B.B.S.....

Name & Address of the Office / Department : P.H.C. Kondha

To Mother Teresa Public School, Kondha
(Name & Address of the Institution)

Medical Officer
Primary Health Center Kondha

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Senior Geologist Office
Ground Water Survey & Development.
Sub Divisional laboratory, Lakhandur. Dist. Bhandara.

जा.क्र./भुसविय/उपविप्र. लांबादुर/22-08/2025

दि 03/09/2025

WATER ANALYSIS REPORT

Name of Sender – sharad krushnaji humane

Date of Receipt - 05.08.2025

Date of Examination: 18.08.2025

Types of source- R.O .

Location :- *Methhey Teresa School, Konda Kosaja*

(All the Analytical Results are in mg /L.except pH & Turbidity Conductivity)

SR.NO	TEST PARAMETER	BIS Specifications 10500 : 2004 (Edn.2.2) Normal Values		Sample Test Result
		Desirable Limits	Permissible Limits	
1	Physical Observations	--	--	Agreeable
2	Odour	Unobjectionable	--	Agreeable
3	Turbidity (N.T.U.)	1.0	5	0.49
4	Temp	°C	°C	25
5	pH Value	6.5 to 8.5	No Relaxation	7.0
6	Chlorides (as Cl)	250	1000	175
7	Nitrates (as NO ₃)	45	No Relaxation	15.150
8	Total Hardness (as CaCO ₃)	200	600	300
9	Alkalinity (as CaCO ₃)	200	600	260
10	Iron (as Fe)	0.3	1.0	0.001
11	Fluoride (as F)	1.0	1.5	0.500
12	Total Dissolved Solids	500	2000	540
13	Sulphate (as SO ₄)	200	400	49.460
14	EC (Conductivity)	--	--	830
15	Magnesium(Mg)	30	100	68.234
16	Calcium	75	200	19.2

Remark- Above Sample is fit for drinking purpose on the basis of above Analysis.

- ☐ This Report is restricted only for the sample submitted to this laboratory.
- ☐ It is presumed that the representative sample from the source is sent for analysis.

[Signature]
Signature & Seal

Chemist

Sub Divisional Laboratory Lakhandur

[Signature]
Assistant Junior Geologist
G.S.D.A. BHANDARA

[Signature]
Senior Geologist
G.S.D.A. BHANDARA